

**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**DISTRICT WATER TESTING LABORATORY, HISAR**

ANNEXURE-X-D

25



Website :- <https://phedharyana.gov.in/>

Memo No:- 1682

Date:- 20/10/2022

Subject: **Physical / Chemical Examination Report of Water Sample**

HC-559

Sample ID/Classification :	HSR/01994/10/2022 / Private	Sample Details	Date & Time
Sender :	MODERN DEFENCE SCHOOL15931	Collected By	
Location :	, 7th KM Storie Kaimri Road Hisar	Collection Date	19/10/2022 at 12:27
Sample Description :	Drinking Water	Received at lab	19/10/2022 at 13:48
Latitude / Longitude :	75.722086 / 29.096112	Analysis Start Date	19/10/2022
		Analysis End Date	20/10/2022
		Sample Quantity	2 ltr.

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	217	500 mg/lit.	2000 mg/lit.	APHA2540 C; 2017
2	Total Hardness as CaCo3	64	200 mg/lit.	600 mg/lit.	APHA2340 C; 2017
3	Calcium as Ca	12.83	75 mg/lit.	200 mg/lit.	APHA3500-Ca B; 2017
4	Magnesium as Mg	7.78	30 mg/lit.	100 mg/lit.	APHA3500 Mg B; 2017
5	Iron as Fe	0.01	1.0 mg/lit.	1.0 mg/lit.	APHA3500-Fe B; 2017
6	Chloride as Cl	68	250 mg/lit.	1000 mg/lit.	APHA4500 Cl-B; 2017
7	Sulphate as So4	62	200 mg/lit.	400 mg/lit.	APHA4500-So4-E
8	Fluoride as F	0.08	1.0 mg/lit.	1.5 mg/lit.	APHA 4500-F--C
9	Nitrate as No3	0.09	45 mg/lit.	45 mg/lit.	APHA 4500-NO3- D
10	pH @ 25°C	7.99	6.5 - 8.5	6.5 - 8.5	APHA4500-H+ B; 2017
11	Total Alkalinity	40	200 mg/lit.	600 mg/lit.	APHA 2320 B; 2017

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters, the water sample is found "**POTABLE**"



Sample analyzed by :

*Handwritten signature*

RAJEEV KUMAR, CHEMIST  
DISTRICT WATER TESTING LABORATORY, HISAR  
email:-chemist.hisar@phedharyana.gov.in

*Handwritten signature*

*Handwritten signature*  
**Principal**  
**Modern Defence School**  
**Affiliation Code- 531127**  
**School Code- 41091**